

# Higher Education Energy Efficiency Partnership Program

## BEST PRACTICES AWARDS

UC / CSU Sustainability Conference, June 2005




*A program created by the  
UC/CSU/IOU Partnership  
and under the auspices of the  
California Public Utilities Commission*

**UC San Diego**

**Supercomputer Center**

**Craig Johnson, PE**



**Rumsey Engineers Inc**

Peter Rumsey, Cindy Regnier

**EHDD Architecture**

Richard Feldman

**NaturalWorks Engineering Consultants**


Paul F. Linden, Guilherme Carrilho da Graça.

**L B N L - Commercial Building Systems Group**


Philip Haves




# Displacement Ventilation with Hot Water Radiators



typical section : displacement ventilation



SCH. DSGN



TYP. FLOOR PLAN





Inland Revenue Service - UK



**Saga Group, Folkestone, UK**



Cambridge, UK



Ceramique Office, Maastricht, NL



Saga Group, Folkestone, UK

# Engineering

- Creativity
- Science

# Engineering

- Creativity
- Science
- Every building is a new opportunity
- Prove it

# Generic design objectives

- First, ensure that the HVAC system meets the needs of the building occupants
- Second, deliver this environment as efficiently as possible







# Environmental Issues

- Fog
- Airborne salt
- Airborne particles
- Santa Ana conditions
- Solar loads (esp. in winter)





CHS →

← CHR

AH-5  
3rd. Flr South





# Supercomputer design objectives

- Create an acceptable indoor environment throughout the year
- Construction cost to be equal to, or below, what a conventional system would cost (VAV – terminal reheat)
- HVAC system that is more efficient than a conventional system



$$\begin{aligned}
 \text{PMV} = & \quad (0.303e^{-0.036M} + 0.028) \{ (M - W) - 3.05 \times 10^{-3} \times \\
 & [5733 - 6.99(M - W) - p_a] - 0.42 \times [(M - W) - 58.15] - 1.7 \times \\
 & 10^{-5} M(5867 - p_a) - 0.0014M(34 - t_a) - 3.96 \times 10^{-8} f_{cl} \times [(t_{cl} + \\
 & 273)^4] - (t_r + 273)^4] - f_{cl} h_c (t_{cl} - t_a) \}
 \end{aligned}$$



# Significant design factors

- To produce simple and efficient designs we need to hire wiser designers (wisdom is more critical than knowledge)
- The mechanical engineering firm is accountable for indoor comfort levels
- The University needs to play a role in the selection of the mechanical consultant

# **San Diego Supercomputer Center**

Performance simulation of the indoor climate control system

Optimization of the shading design

NaturalWorks Engineering Consultants

Paul F. Linden, Guilherme Carrilho da Graça.

L B N L - Commercial Building Systems Group

Philip Haves

# Presentation Contents

Introduction


1- Site climate analysis

2- EnergyPlus simulation of indoor conditions

3- Analysis of external shading systems

Conclusions


# 1 - Climate analysis



Variation of maximum and minimum temperature (degrees F) in San Diego for the two typical weather years, measured at San Diego airport, used in the analysis (1966 and a composition of 1988 and other years).

# 1 - Climate analysis:

....where does the wind blow during warm hours?



Daytime analysis only considered hours in “warm” days where wind is significant i.e when the wind velocity is above 3mph.


A day is considered warm if the maximum outside dry bulb temperature is higher than 26°C (79°F).

# 1 - Climate analysis - night cooling:

....what is the minimum temperature at night after each warm day?

Daily variation of **maximum** (red) and **minimum** (black) temperature for “warm” and mildly warm days (max.  $T_{out} > 70^\circ F$ ).

The data consist of selected days for the second weather year shown in figure 1.



Potential for night cooling in San Diego is moderate. Still, since the climate is generally mild during the day, the small amount of night cooling that can be achieved in most days may be sufficient.

Post processing of the data in the previous slide shows that the wind blows from an angle (A):  $340 > A > 160$  (i.e from northwest to south) for 72% of the time.



# 1 - "Onsite" climate analysis

There are no systematic historic weather data records for UCSD campus locations

Local topography influence and proximity to the sea make Carlsbad a close representation to campus, sea influenced conditions

Available typical weather files use data measured at SAN

As expected San Diego Airport temperature measurements are higher than Carlsbad, how much...?



## Data and method used in the analysis

Two typical weather data years, using data measured at the San Diego Airport (SAN): 1966 and a composition of 1988 and other years (the year used changes on a monthly basis)

Five years of temperature and wind data measured in the Carlsbad weather station (1999, 2000, 2001, 2002 and 2003)


Steps taken:

- 1- A representative year for the Carlsbad (KCRQ) weather data was selected (conservatively we used one of the warmer years)
- 2- The two SAN and the representative KCRQ year were compared (analysis of maximum and minimum daily temperatures, running averages and degree hours above different temperatures)
- 3- A matching of degree hours above relevant cooling analysis temperatures (Tout above 26°C, 79°F) was obtained by decreasing the SAN 1988 dry bulb temperature

## Degree-hour analysis

Variation of degree hours above a given base temperature for the 7 years analysed

As discussed above, KCRQ03 is cooler than SAN (1988) and SAN (1966).



Base T (°F)	SAN 88	SAN 66	KCRQ03
68	5684	4536	3442
72	2363	1898	1369
75	887	689	494
<b>79</b>	<b>334</b>	<b>276</b>	<b>147</b>
82	104	131	33

# TMY adjustment



TMY (SAN 1988) and KCRQ03 maximum and minimum daily temperatures

Before adjustment


After adjustment

The typical colder climate of the site is approximately represented by the SAN 1988 data by using a negative offset in the air temperature, obtaining an adjust weather year:

$$\text{Adjusted} = \text{SAN} - 2.5 \text{ } ^\circ\text{F}$$



## 2- EnergyPlus simulation of indoor conditions



## **2- EnergyPlus Simulations**

The proposed design was modelled using EnergyPlus (closely following design documentation and usage schedules)

The model has 77 independent thermal zones, and more than 700 surfaces

The geometry was “zoned” as shown in the next slides

Two weather files were used: SAN TMY 1988 and SAN TMY 1988 Adjusted to Carlsbad

## 2- EnergyPlus Simulations

In all zones, internal gains were set to approximately:

***Occupants:*** one occupant every 100sft/10 m<sup>2</sup> =>13 W/ m<sup>2</sup>

***Lights:*** 10 W/ m<sup>2</sup>

***Equipment:*** 33 W/ m<sup>2</sup>

*Each occupant introduces a gain of 120W and uses a PC/Printer of 300W*

In order to test the ability to support higher gains one of the single occupant offices tested was loaded with two occupants

In addition other design variations were tested:

Standard clear glazing (**SG**)

No external insulation in the vertical envelope walls (**NI**)

Optimized, smaller shading devices (**SS**)

Lower gains: one occupant per office (in all closed offices) and half occupancy in the core zones (**LG**)

## **Outside air / ventilation scenarios considered, free running building:**

In order to assess the importance of the ventilation strategy in the cooling period we analysed three ventilation strategies:

Standard fixed flow:

**V00:**      day 1.5 Ach/h      night 0.5 Ach/h

Variable ventilation (depends on temp. difference):

**VD0:**      day 1.5-5 Ach/h      night 10-15 Ach/h

Variable ventilation with maximum night cooling (depends on temp. difference):

**VDN:**      day 1.5-5 Ach/h      night 15-30 Ach/h

## **Mechanical cooling (can be cooled inflow air, fan coil, chilled/heated slab...):**

**PA:** In this case inside temperature is kept between 65 and 77°F. Minimum outside air is always insured (15l/s per occupant).


In order to assess the advantages of hybrid cooling the mechanical system can be combined with any of the three ventilation scenarios above.



# Zoning of floors 0&1




# Zoning of floors 2&3




Zone AR02


SOUTH BUILDING, FLOOR 0



Zone AR07 SOUTH BUILDING, FLOOR 3




Zone AR08 NORTH BUILDING, FLOOR 3






Zone AR09

SOUTH BUILDING, FLOOR 3




Base case:  
 Standard weather  
 No mechanical cooling  
 Variable ventilation strategy

Number of hours in a given  
 Temperature interval



## Average impact of the ventilation scheme




Ventilation Schemes: Low (V00), Daytime (VD0), Night&Day (VDN)






Adjusted weather  
 No mechanical cooling  
 Variable ventilation strategy

Number of hours in a given  
 Temperature interval




## Impact of local weather


Ventilation analysis with adjusted weather




## Impact of glazing system




## Impact of external wall insulation



# Impact of optimized smaller shading (increased gains in winter)



# Impact of lower gains



# Mechanical heating and cooling

Maximum Cooling Load (normalized to the maximum zone load)

ZONE	V00 PA	VD0 PA	VDN PA	VDN PA LG	VDN PA SS
AR02	<b>1.00 (102W/m<sup>2</sup>)</b>	0.99	0.95	0.73	0.95
AR07	0.91	0.95	0.83	0.68	0.84
AR08	0.70	0.69	0.65	<b>0.48</b>	0.65
AR09	0.72	0.72	0.65	0.53	0.65

Total Cooling Energy (normalized to the maximum zone load)

ZONE	V00 PA	VD0 PA	VDN PA	VDN PA LG	VDN PA SS
AR02	0.89	0.61	0.55	0.32	0.56
AR07	<b>1.00</b>	0.62	0.51	0.36	0.52
AR08	0.74	0.45	0.38	<b>0.22</b>	0.39
AR09	0.72	0.43	0.37	0.26	0.37




ZONE	Max. Heating Load (normalized)		Total Heating Energy (normalized)	
	V00 PA	V00 NI PA	V00 PA	V00 NI PA
AR02	0.72	<b>1.00 (97W/m<sup>2</sup>)</b>	0.50	<b>1.00</b>
AR07	0.60	0.95	<b>0.17</b>	0.84
AR08	<b>0.54</b>	0.66	0.24	0.49
AR09	0.57	0.58	0.36	0.38

### 3- Shading analysis using ECOTEC


Initial proposal

Optimized shading

Lowered shading









Lowered shading  
With day lighting reflector

# S-BASE (size 1.2m)



# S-OPTIM BASE (0.75m)










# N-LOW (.47m)



## Preliminary conclusions

The San Diego climate has significant potential for low energy climate control systems

In the current design phase it may still be possible to improve performance by placing higher load spaces in the North façade (why not the computer labs?)

In most spaces the use of natural cooling by single sided displacement ventilation (both during the day and night) may provide sufficient cooling

Due to the mildness of the climate, “special glazing” or even thermal insulation in the vertical walls may not be necessary

The use of ducted forced air in the perimeter offices may not be an appropriate solution since large flow rates are needed in order to maximize natural cooling (easier to obtain with natural ventilation)



# Building features

- Low capacity AHU (fan and coils)
- Mist eliminators and filters in the AHU
- No terminal boxes or controls in the distribution system
- Low sidewall diffusers with damper
- Operable windows
- Relief of all supply air

# Building features (cont.)

- Local chilled water loop to manage point loads
- Sun shades

existing  
supercomputer  
offices




- collaborative space
- meeting room
- lab
- offices
- circulation / service
- existing building


### FLOOR PLAN - LEVEL 3




# Displacement Ventilation with Hot Water Radiators




typical section : displacement ventilation





### San Diego Weather Data



# Supercomputer Office HVAC Features

- “Hybrid System”
- Push air through the building – use two air handlers on the roof sized for 1.5 cfm/sf, 60,000 cfm and 90,000 cfm
- Each air handler has mist eliminator, filters, heating coil and cooling coil (for cooling and/or dehumidification)
- Approximately 1,000 sf/ton, 15 btuh/sf
- On moderate temperature days air is neither heated or cooled and supplied at 1.5 cfm/sf
- On hot days air is cooled to 70-72 deg F and supplied at 0.3 cfm/sf. Night time cooling of thermal mass is used
- On cold days air is heated to 70-72 deg F and supplied at 0.3 cfm/sf
- Air is supplied down low for user operability and displacement ventilation / stratification reasons – heat from lights is excluded from occupied zone
- Alternative – supply air from above - do full mixing, heat from lighting system is included in occupied zone
- Alternative – downsize air handlers and ducting to ventilation only requirements to lower cost. Size for 0.2 – 0.4 cfm /sf



# Capital Costs

## UCSD Supercomputer Center - HVAC Systems

### Capital Expenses

	90% Schematic Design Mechanical System - HYBRID System	Alternative - Ventilation Air Only accepting VE Items 42 and 44	Traditional Overhead VAV System
Offices	\$ 2,210,000	\$ 1,525,000	\$ 2,540,000
Process Cooling	\$ 419,000	\$ 419,000	Handled with VAV system
Machine Room	\$ 735,000	\$ 735,000	\$ 735,000
Plant	\$ 644,000	\$ 644,000	\$ 644,000
<b>Total Cost</b>	<b>\$ 4,008,000</b>	<b>\$ 3,323,000</b>	<b>\$ 3,919,000</b>
Total Cost Per SF assuming 80,000 sf	\$ 50.10	\$ 41.54	\$ 48.99
Other Deducts - Steel Building, Lower Partition Walls			\$ (490,000)
Other Adds - Drop Ceiling			\$ 110,000
<b>Effective Cost Impact</b>	<b>\$ 4,008,000</b>	<b>\$ 3,323,000</b>	<b>\$ 3,539,000</b>

# Energy Costs

## Energy Expenses

	90% Schematic Design Mechanical System - HYBRID System	Alternative - Ventilation Air Only accepting VE Items 42 and 44	Traditional Overhead VAV System
Estimated Annual Energy Costs - All End Uses*	\$ 168,000	\$ 112,000	\$ 280,000
Estimated Annual Energy Costs - HVAC Only	\$ 67,200	\$ 44,800	\$ 112,000
<b>Anticipated HVAC Costs Savings</b>	<b>\$ 44,800</b>	<b>\$ 67,200</b>	<b>N/A</b>
<b>20 Year Cost Savings</b>	<b>\$ 896,000</b>	<b>\$ 1,344,000</b>	

HVAC and Lighting Energy Savings will be possible in the as designed building

# Why did this happen

- Culture in FD&C
- FD&C staff engineers
- Direct communication between FD&C engineers and mechanical engineers
- Interaction with operations staff

# Risks to the design approach

- Setpoint changes
- Load density
- Increase in warm weather days
- Accuracy of the model