


# **An Application of Life-Cycle Cost Analysis at UC Davis**

## **Veterinary Medicine Instructional Facility**

**Bill Starr, Senior Project Manager, UCD  
Martyn Dodd, Principal, EnergySoft**




**UC Sustainability Conference, June 2005**




Project Site

Project Location  
Veterinary Medicine Instructional Facility  
UNIVERSITY OF CALIFORNIA, DAVIS



# Site Plan





## First Floor Plan

Veterinary Medical Instructional Facility  
UNIVERSITY OF CALIFORNIA, DAVIS

**SRG PARTNERSHIP INC**

---

# Information Gathering

- Client Input
  - Study Period
  - Real Discount Rate
  - Utility Rates
  - Energy Price Escalation Rates??
  - Study Measures

## **Real Discount Rate**

The rate of interest reflecting the portion of the time value of money attributable to the real earning power of money over time and not to general price inflation.

---

# Information Gathering

- Design Team Input
  - Study Measures
  - Incremental Costs
  - O&M Costs
  - Replacement Costs

---

# Information Gathering

- Energy Analyst Input
  - Energy Consumption Estimate (Energy Model)
  - Energy Cost Estimate
  - Savings Estimates for Study Measures
  - Rebates and Incentives (Savings by Design)

# Calculations

- Simple Payback

- Life Cycle Costing

- NIST Handbook 135

*Life-Cycle Costing Manual for the Federal Energy Management Program*

## LIFE CYCLE COSTING SUMMARY LCC-1

PROJECT NAME UC Davis Vet Med Instructional Facility	DATE 12/18/2002
---	--------------------

### Annual Energy Use and Cost

Option	Description	Electricity			Natural Gas		Simple Payback (years)
		Consumption (kWh)	Demand (kW)	Cost (\$)	Consumption (therms)	Cost (\$)	
Base	Base Case (No Evap Cooling or Daylighting, 24" Stud)	1,003,492	352	\$ 67,693	3,606	\$ 2,074	N/A
1	Increase Roof Insulation to 4"	1,002,308	352	\$ 67,595	3,668	\$ 2,109	441.6
2	Decrease stud spacing from 24" to 16"	1,004,563	353	\$ 67,786	4,200	\$ 2,415	0.0
3	Daylighting Controls	971,867	346	\$ 65,636	4,151	\$ 2,387	9.5
4	Indirect Evaporative Cooling on AHU-1 & AHU-2	926,814	346	\$ 62,142	3,826	\$ 2,200	2.1
5	Indirect Evap on AHU-1/2 and Daylighting Controls	899,072	340	\$ 60,319	4,169	\$ 2,397	4.2
6	Skylighting Reduction	1,003,018	352	\$ 67,652	3,627	\$ 2,086	0.0
7	Bundle: ECM 3 + ECM 6	969,264	346	\$ 65,463	4,169	\$ 2,398	0.0
8	Bundle: ECM 3 + ECM 4 + ECM 6	893,195	339	\$ 59,943	4,203	\$ 2,417	0.0
9	Glazing changed to Solarban 60 Green	998,591	352	\$ 67,317	3,749	\$ 2,156	13.3

### Life Cycle Cost Present Value

Option	Initial Cost	Utility Incentive	Annual Recurring Costs	Electricity Costs	Natural Gas Costs	Non Annual Recurring OM&R Cost	Replacement Costs	Residual Value	Total LCC
Base	\$ 0	\$ 32,429	\$ 0	\$ 1,325,149	\$ 38,087	\$ 0	\$ 0	\$ 0	\$ 1,330,807
1	\$ 27,000	\$ 31,607	\$ 0	\$ 1,323,231	\$ 38,730	\$ 0	\$ 0	\$ 0	\$ 1,357,353
2	\$ 15,000	\$ 29,687	\$ 0	\$ 1,326,970	\$ 44,349	\$ 0	\$ 0	\$ 0	\$ 1,356,632
3	\$ 22,900	\$ 38,790	\$ 0	\$ 1,284,882	\$ 43,835	\$ 0	\$ 0	\$ 0	\$ 1,312,826
4	\$ 31,700	\$ 52,717	\$ 40,856	\$ 1,216,483	\$ 40,401	\$ 1,245	\$ 776	\$ 0	\$ 1,278,744
5	\$ 54,600	\$ 57,427	\$ 40,856	\$ 1,180,797	\$ 44,018	\$ 1,245	\$ 776	\$ 0	\$ 1,264,865
6	\$ -50,000	\$ 32,398	\$ 0	\$ 1,324,346	\$ 38,307	\$ 0	\$ 0	\$ 0	\$ 1,280,256
7	\$ -27,100	\$ 39,440	\$ 40,856	\$ 1,281,495	\$ 44,037	\$ 1,245	\$ 0	\$ 0	\$ 1,301,094
8	\$ 4,600	\$ 58,460	\$ 40,856	\$ 1,173,436	\$ 44,386	\$ 1,245	\$ 0	\$ 0	\$ 1,206,064
9	\$ 5,000	\$ 33,508	\$ 0	\$ 1,317,788	\$ 39,593	\$ 0	\$ 0	\$ 0	\$ 1,328,873

### Study Parameters

Study Period: 30 years  
 Real Discount Rate: 6.1%  
 DOE/FEMP Escalation Rates  
 Region: N/A  
 Fuel Sector: N/A  
 Uniform Escalation Rates  
 Electricity: 3.0%  
 Natural Gas: 2.5%

### Life Cycle Cost Savings



# Interpreting the Results

- Results are not always cumulative
  - Example – Better Chiller and Better Windows
- SBD Incentives are designed to Escalate as savings Increase
- Decide on Combined Measures
- Incentives escalate as packages of measures are created
- Create package of measures based upon client input

